



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

July 12, 2016

Kerry Blake
Siuslaw School District
2111 Oak Street
Florence, OR 97439
TEL:
FAX

RE:

Order No.: 1607216

Dear Kerry Blake:

Analytical Laboratory Group received 10 sample(s) on 7/6/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 1607216
Date: 7/12/2016

CLIENT: Siuslaw School District

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.



WO#: 1607216
CLIENT: Siuslaw School District
Project:
PWS Number:
Sample Source:

Received Date: 7/6/2016 3:30:00 PM
Sampler Name: Cary Pinnock
Matrix: Drinking Water
Sample Type:

Lab ID: 1607216-001 **Client Sample ID** HS Main Gym SE Corner **Collection Date:** 7/6/2016 7:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-002 **Client Sample ID** Prim North Hall Fountain **Collection Date:** 7/6/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00465	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-003 **Client Sample ID** Prim North Sink/ Right side of Rm **Collection Date:** 7/6/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00443	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-004 **Client Sample ID** Prim North Nurse Room **Collection Date:** 7/6/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00248	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-005 **Client Sample ID** Elem South Rm #6 **Collection Date:** 7/6/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00266	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-006 **Client Sample ID** Elem South Front Ent. Hall Fountai **Collection Date:** 7/6/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-007 **Client Sample ID** MS 8th Grade Hall Ftn by RR **Collection Date:** 7/6/2016 7:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Lab ID: 1607216-008 **Client Sample ID** MS Ftn at base of commons stairs **Collection Date:** 7/6/2016 7:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00356	0.0200	0.00200		mg/L	7/9/2016 10:07:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported 7/12/2016

WO#: 1607216
CLIENT: Siuslaw School District
Project:
PWS Number:
Sample Source:

Received Date: 7/6/2016 3:30:00 PM
Sampler Name: Cary Pinnock
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID				Collection Date:		
1607216-009	HS outside of Girls Mall RR				7/6/2016 7:30:00 AM		
Analyses	Method	Result	MCL	RL Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	7/9/2016 10:07:00 AM	KG

Lab ID:	Client Sample ID				Collection Date:		
1607216-010	HS Upstairs Fountain				7/6/2016 7:30:00 AM		
Analyses	Method	Result	MCL	RL Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	7/9/2016 10:07:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607216
 12-Jul-16

Client: Siuslaw School District

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607216-001A	HS Main Gym SE Corner	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607216-002A	Prim North Hall Fountain			Lead	A
	1607216-003A	Prim North Sink/ Right side of Rm #26 Entrance			Lead	A
	1607216-004A	Prim North Nurse Room			Lead	A
	1607216-005A	Elem South Rm #6			Lead	A
	1607216-006A	Elem South Front Ent. Hall Fountain			Lead	A
	1607216-007A	MS 8th Grade Hall Ftn by RR			Lead	A
	1607216-008A	MS Ftn at base of commons stairs			Lead	A
	1607216-009A	HS outside of Girls Mall RR			Lead	A
	1607216-010A	HS Upstairs Fountain			Lead	A

ORELAP A Accredited

ACCRED

Original #1607216# v1

Page 5 of 7



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607216

Date: 7/12/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definition Base

WO#: 1607216
Date: 7/12/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



Delivering more than just test results.

CHAIN OF CUSTODY

Attention: Kerry Blake	Client: Siuslaw School District
Phone: 541-997-2651	Address: 2111 Oak Street
Email: AGRZESKOWIAK@siuslaw.k12.or.us	City, State, Zip: Florence, OR 97439
Client Project:	Sampler: Print Cary Pinnock
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
HS Main Gym SE Corner	DN/Grab	7-6-16	0730	Lead	P	1			001A
Prim North Hall Fountain			0830						002A
Prim North Sink	Right side of Rm #26 E.H.		0830						003A
Prim North Nurse Rm			0830						004A
Elem South Rm #6			0830						005A
Elem South Front Ent. Hall Ftn			0830						006A
MS 8th grade Hall Ftn by RR			0755						007A
MS Ftn at base of commons stairs			0755						008A
HS outside of Girls Mall RR			0730						009A
HS Upstairs ftn			0730						010A

Notes: Sample Info per client 7/8/16 SAH	Preservation Check																																													
	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																								
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																										

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated: NA
Relinquished by:	Date Time	Received by: Date Time
Relinquished by:	Date Time	Received by: Date Time
Relinquished by:	Date Time	Received by Laboratory: Date Time
		SAH 7/6/16 1530



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

September 06, 2016

Andy Grzeskowiak
Siuslaw School District
2111 Oak Street
Florence, OR 97439
TEL: (541) 997-2651
FAX

RE:

Order No.: 1608B55

Dear Andy Grzeskowiak:

Analytical Laboratory Group received 20 sample(s) on 8/24/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1608B55

Date: 9/6/2016

CLIENT: Siuslaw School District

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1608B55
CLIENT: Siuslaw School District
Project:
PWS Number:
Sample Source:

Received Date: 8/24/2016 4:00:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID:	Client Sample ID	Collection Date:						
1608B55-001	1	8/23/2016 10:30:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-002	2	8/23/2016 10:25:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-003	3	8/23/2016 10:21:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-004	4	8/23/2016 10:17:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-005	5	8/23/2016 10:11:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00356	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-006	6	8/23/2016 10:06:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-007	7	8/23/2016 10:01:00 A						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID:	Client Sample ID	Collection Date:						
1608B55-008	8	8/23/2016 9:54:00 AM						
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1608B55
CLIENT: Siuslaw School District
Project:
PWS Number:
Sample Source:

Received Date: 8/24/2016 4:00:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID: 1608B55-009 **Client Sample ID:** 9 **Collection Date:** 8/23/2016 9:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID: 1608B55-010 **Client Sample ID:** 10 **Collection Date:** 8/23/2016 9:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00244	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID: 1608B55-011 **Client Sample ID:** 11 **Collection Date:** 8/23/2016 9:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID: 1608B55-012 **Client Sample ID:** 12 **Collection Date:** 8/23/2016 9:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00213	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID: 1608B55-013 **Client Sample ID:** 13 **Collection Date:** 8/23/2016 9:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00252	0.0200	0.00200		mg/L	9/3/2016 7:20:00 AM	PG

Lab ID: 1608B55-014 **Client Sample ID:** 14 **Collection Date:** 8/23/2016 9:17:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Lab ID: 1608B55-015 **Client Sample ID:** 15 **Collection Date:** 8/23/2016 9:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1608B55
CLIENT: Siuslaw School District
Project:
PWS Number:
Sample Source:

Received Date: 8/24/2016 4:00:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID: 1608B55-016 **Client Sample ID:** 16 **Collection Date:** 8/23/2016 8:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00247	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Lab ID: 1608B55-017 **Client Sample ID:** 17 **Collection Date:** 8/23/2016 8:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00221	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Lab ID: 1608B55-018 **Client Sample ID:** 18 **Collection Date:** 8/23/2016 8:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Lab ID: 1608B55-019 **Client Sample ID:** 19 **Collection Date:** 8/23/2016 8:37:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Lab ID: 1608B55-020 **Client Sample ID:** 20 **Collection Date:** 8/23/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/4/2016 8:40:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1608B55

Date: 9/6/2016

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

P3

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

PUC

CHAIN OF CUSTODY

Attention: Kerry Blake	Client: Siuslaw School District
Phone: 541-997-2651	Address: 2111 Oak Street
Email: agrzeskowiak@siuslaw.k12.or.us	City, State, Zip: Florence, OR 97439
Client Project:	Sampler: Print <i>Cary Pinnock</i>
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
1	DW/Grab	8/23/16	10:30am	Lead	P	1			001A
2	DW/Grab	8/23/16	10:25am	Lead	P	1			002A
3	DW/Grab	8/23/16	10:21am	Lead	P	1			003A
4	DW/Grab	8/23/16	10:17am	Lead	P	1			004A
5	DW/Grab	8/23/16	10:11am	Lead	P	1			005A
6	DW/Grab	8/23/16	10:06am	Lead	P	1			006A
7	DW/Grab	8/23/16	10:01am	Lead	P	1			007A
8	DW/Grab	8/23/16	9:54am	Lead	P	1			008A
9	DW/Grab	8/23/16	9:50am	Lead	P	1			009A
10	DW/Grab	8/23/16	9:42am	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <i>ALG CARRIER</i>	Refrigerated <i>NA</i>
---	------------------------------------	---------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	8/24/16	1600	<i>[Signature]</i>	8/24/16	1313
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	8/24/16	1600	<i>[Signature]</i>	8/24/16	1600

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

NPUC

CHAIN OF CUSTODY

Attention: Kerry Blake	Client: Siuslaw School District
Phone: 541-997-2651	Address: 2111 Oak Street
Email: agrzeskowiak@siuslaw.k12.or.us	City, State, Zip: Florence, OR 97439
Client Project:	Sampler: Print <i>Cary Pinnock</i>
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
11	DW/Grab	8/23/16	9:39 am	Lead	P	1			011A
12	DW/Grab	8/23/16	9:31 am	Lead	P	1			012A
13	DW/Grab	8/23/16	9:23 am	Lead	P	1			013A
14	DW/Grab	8/23/16	9:17 am	Lead	P	1			014A
15	DW/Grab	8/23/16	9:05 am	Lead	P	1			015A
16	DW/Grab	8/23/16	8:56 am	Lead	P	1			016A
17	DW/Grab	8/23/16	8:50 am	Lead	P	1			017A
18	DW/Grab	8/23/16	8:42 am	Lead	P	1			018A
19	DW/Grab	8/23/16	8:37 am	Lead	P	1			019A
20	DW/Grab	8/23/16	8:30 am	Lead	P	1			020A

Notes:	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																		
Preservation Check																																																													
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																									

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG CARRIER	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>			<i>[Signature]</i>	8/24/16	1313
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	8/24/16	1600	<i>[Signature]</i>	8/24/16	1600



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

September 29, 2016

Kerry Blake
Siuslaw School District
2111 Oak Street
Florence, OR 97439
TEL: (541) 997-2651
FAX

RE: Siuslaw

Order No.: 1609A32

Dear Kerry Blake:

Analytical Laboratory Group received 20 sample(s) on 9/21/2016 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 1609A32
Date: 9/29/2016

CLIENT: Siuslaw School District
Project: Siuslaw

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1609A32
CLIENT: Siuslaw School District
Project: Siuslaw
PWS Number:
Sample Source:

Received Date: 9/21/2016 2:40:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID: 1609A32-001 **Client Sample ID** 1. Trans Breakroom Sink **Collection Date:** 9/20/2016 7:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00252	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-002 **Client Sample ID** 2. Alt School Entry Fountain **Collection Date:** 9/20/2016 7:43:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-003 **Client Sample ID** 3. Alt West Class Sink **Collection Date:** 9/20/2016 7:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00758	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-004 **Client Sample ID** 4. Alt East Class Sink **Collection Date:** 9/20/2016 7:46:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00890	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-005 **Client Sample ID** 5. Stadium Concessions **Collection Date:** 9/20/2016 7:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-006 **Client Sample ID** 6. EC Cares - West Room Fountain **Collection Date:** 9/20/2016 7:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-007 **Client Sample ID** 7. D.O. Sink **Collection Date:** 9/20/2016 8:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00314	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-008 **Client Sample ID** 8. SHS Main Gym SE Fountain **Collection Date:** 9/20/2016 8:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609A32
CLIENT: Siuslaw School District
Project: Siuslaw
PWS Number:
Sample Source:

Received Date: 9/21/2016 2:40:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID: 1609A32-009 **Client Sample ID** 9. SHS Aux Gym Fountain **Collection Date:** 9/20/2016 8:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-010 **Client Sample ID** 10. Culinary - Demo Station **Collection Date:** 9/20/2016 8:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-011 **Client Sample ID** 11. SHS Culinary Station #2 **Collection Date:** 9/20/2016 8:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-012 **Client Sample ID** 12. SMS Main Gym NE **Collection Date:** 9/20/2016 8:33:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-013 **Client Sample ID** 13. SMS Main Gym SW **Collection Date:** 9/20/2016 8:35:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-014 **Client Sample ID** 14. SMS Aux Gym East **Collection Date:** 9/20/2016 8:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-015 **Client Sample ID** 15. SMS Aux Gym West **Collection Date:** 9/20/2016 8:36:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1609A32
CLIENT: Siuslaw School District
Project: Siuslaw
PWS Number:
Sample Source:

Received Date: 9/21/2016 2:40:00 PM
Sampler Name: Cary Pinnock
Matrix:
Sample Type:

Lab ID: 1609A32-016 **Client Sample ID:** 16. SMS Kitchen Prep Sink **Collection Date:** 9/20/2016 8:41:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-017 **Client Sample ID:** 17. SES Kitchen Prep Sink **Collection Date:** 9/20/2016 8:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-018 **Client Sample ID:** 18. SES Classroom #32 **Collection Date:** 9/20/2016 9:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-019 **Client Sample ID:** 19. SES Classroom #35 **Collection Date:** 9/20/2016 8:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Lab ID: 1609A32-020 **Client Sample ID:** 20. Kinder Entrance Fountain **Collection Date:** 9/20/2016 8:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	9/27/2016 3:57:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1609A32

Date: 9/29/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Definition Base

WO#: 1609A32
Date: 9/29/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Kerry Blake	Client: Siuslaw School District
Phone: 541-997-2651	Address: 2111 Oak Street
Email: agrzeskowiak@siuslaw.k12.or.us	City, State, Zip: Florence, OR 97439
Client Project: Siuslaw	Sampler: Print Cary Pinnock
	Sampler: Signature <i>KU Blake</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only					
		Date	Time		Type	#	Pres	T °C	Lab ID	
1) Trans Breakroom Sink	DW/Grab	9/20/16	7:39	Lead	P	1			001A	
2) Alt School entry Fountain	DW/Grab		7:43	Lead	P	1			002A	
3) Alt West class Sink	DW/Grab		7:44	Lead	P	1			003A	
4) Alt East class Sink	DW/Grab		7:46	Lead	P	1			004A	
5) Stadium Concessions	DW/Grab		7:53	Lead	P	1			005A	
6) EC Cares - West room Fountain	DW/Grab		7:59	Lead	P	1			006A	
7) D.O. Sink	DW/Grab		8:05	Lead	P	1			007A	
8) SHS main gym SE Fountain	DW/Grab		8:22	Lead	P	1			008A	
9) SHS Aux Gym Fountain	DW/Grab		8:18	Lead	P	1			009A	
10) Culinary - Demo Station	DW/Grab		↓	8:24	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated N/A
---	-----------------------------	---------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>			<i>[Signature]</i>	9/21/16	1150
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	9/21/16	1440	Cynthia O'Kelly	9/21/16	14:40

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Kerry Blake	Client: Siuslaw School District
Phone: 541-997-2651	Address: 2111 Oak Street
Email: agrzeskowiak@siuslaw.k12.or.us	City, State, Zip: Florence, OR 97439
Client Project: Siuslaw	Sampler: Print Cary Pinnock
	Sampler: Signature <i>Kerry Blake</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
11). SHS Culinary station #2	DW/Grab	9/20/16	8:25	Lead	P	1			011A
12). SMS main gym NE	DW/Grab	↓	8:33	Lead	P	1			012A
13). SMS main gym SW	DW/Grab		8:35	Lead	P	1			013A
14). SMS Aux Gym East	DW/Grab		8:38	Lead	P	1			014A
15). SMS Aux Gym West	DW/Grab		8:36	Lead	P	1			015A
16). SMS Kitchen Prep Sink	DW/Grab		8:41	Lead	P	1			016A
17). SES Kitchen Prep Sink	DW/Grab		8:56	Lead	P	1			017A
18). SES Classroom #32	DW/Grab		9:00	Lead	P	1			018A
19). SES Classroom #35	DW/Grab		8:58	Lead	P	1			019A
20). Kinder entrance fountain	DW/Grab		8:53	Lead	P	1			020A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):

NORMAL _____ RUSH _____

Shipped Via: ALG Courier

Refrigerated: N/A

Relinquished by:	Date	Time
Relinquished by:	Date	Time
<i>[Signature]</i>		
Relinquished by:	Date	Time
<i>[Signature]</i>	9/21/16	1440

Received by:	Date	Time
<i>[Signature]</i>		
Received by:	Date	Time
<i>[Signature]</i>	9/21/16	1150
Received by Laboratory:	Date	Time
<i>Cynthia O'Kelly</i>	9/21/16	1440