



Siuslaw School District 97J

2111 Oak Street, Florence, Oregon 97439

Phone 541-997-2651 - Fax 541-997-6748

www.siuslaw.k12.or.us

Water Testing Summary – July & September 2016

Building	Room/Location	Test Results*	Test Date
District Office	General sink, common area	3.14 ppb	9/20/16
Head Start	Fountain, west classroom	ND	9/20/16
Maintenance	Breakroom sink	2.52 ppb	9/20/16
Siuslaw ES	Elementary South - front entrance hall fountain	ND	7/6/16
Siuslaw ES	Elementary South - Room #6 (South room line)	2.66 ppb	7/6/16
Siuslaw ES	Kindergarten entrance fountain	ND	9/20/16
Siuslaw ES	Kitchen preparation sink	ND	9/20/16
Siuslaw ES	Primary North - hall fountain	4.65 ppb	7/6/16
Siuslaw ES	Primary North - nurse's room	2.48 ppb	7/6/16
Siuslaw ES	Primary North - Room #32 (NW room line)	ND	9/20/16
Siuslaw ES	Primary North - Room #35 (NE room line)	ND	9/20/16
Siuslaw ES	Primary North - Room #26, right side-north sink	4.43 ppb	7/6/16
Siuslaw HS	Auxiliary Gym fountain	ND	9/20/16
Siuslaw HS	Culinary Arts - culinary station #2	ND	9/20/16
Siuslaw HS	Culinary Arts - demonstration station	ND	9/20/16
Siuslaw HS	Main Gym - SE corner fountain	ND	7/6/16
Siuslaw HS	Main Gym - SE corner fountain (after service)	ND	9/20/16
Siuslaw HS	Mall fountain - outside girls restroom	ND	7/6/16
Siuslaw HS	Upstairs fountain	ND	7/6/16
Siuslaw MS	Fountain - auxiliary gym East	ND	9/20/16
Siuslaw MS	Fountain - auxiliary gym West	ND	9/20/16
Siuslaw MS	Fountain - lower hall by commons stairs	3.56 ppb	7/6/16
Siuslaw MS	Fountain - main gym NE	ND	9/20/16
Siuslaw MS	Fountain - main gym SW	ND	9/20/16
Siuslaw MS	Fountain - upstairs hall by restrooms	ND	7/6/16
Siuslaw MS	Kitchen preparation sink	ND	9/20/16
Siuslaw West	Fountain, entryway	ND	9/20/16
Siuslaw West	Sink, east classroom - materials prep only	8.90 ppb	9/20/16
Siuslaw West	Sink, west classroom - materials prep only	7.58 ppb	9/20/16
Stadium	Concession stand sink	ND	9/20/16

Test Results* key to codes, abbreviations and references

ppb = parts per billion (a common reporting unit) ND = "not detected at the reporting limit"

- Test reporting limit is 2ppb; concentrations less than 2ppb are not detected by test
- Maximum Contaminant Level allowed by law is 20ppb
- Test result concentrations were reported in mg/L (milligrams per Liter or parts per million) and converted to parts per billion to use a more common value for public reporting.
- Original test reports are on file in at the Siuslaw School District Office.